

Laboratory Report
NYE Report #: 2401640-28902

March 21, 2024

Chautauqua Opportunities Inc.

Project: OCFS Water Testing
OCFS Provider:

Dear Chautauqua Opportunities Inc.,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on March 18, 2024. New York Environmental analyzed the samples on March 19, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.


The USEPA-designated action level for Lead (Pb) in potable water is 0.015 milligrams per liter (0.015 mg/L). The concentration of lead in your samples is listed under the "Result" column.

If there are any further questions regarding the analyses, please feel free to contact us at your convenience at laboratory@nyenvironmental.com. Please include your report number in the subject line of any correspondence.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

We sincerely thank you for participating in the program, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Received:	18 Mar 2024
Date Analyzed:	19 Mar 2024

Analytical Method:	EPA 200.9 Rev. 2.2
OCFS Provider ID	2401640
Analyte, Matrix:	Lead, Potable Water

Lab ID	Client ID	Sample Location/Description	LOQ	Result	Units	Flag
240318R001	1	Grd Flr-KIT Sprayer, First Draw	0.001	0.001	mg/L	
240318R002	2	Grd Flr-KIT Sprayer, 30s Flush	0.001	<0.001	mg/L	
240318R003	3	Grd Flr-KIT-1 Sink Faucet, First Draw	0.001	0.004	mg/L	
240318R004	4	Grd Flr-KIT-1 Sink Faucet, 30s Flush	0.001	0.005	mg/L	
240318R005	5	Grd Flr-KIT-2 Sink Faucet, First Draw	0.001	0.003	mg/L	
240318R006	6	Grd Flr-KIT-2 Sink Faucet, 30s Flush	0.001	<0.001	mg/L	
240318R007	7	Grd Flr-Room G1 Sink Faucet, First Draw	0.001	<0.001	mg/L	
240318R008	8	Grd Flr-Room G1 Sink Faucet, 30s Flush	0.001	<0.001	mg/L	
240318R009	9	Grd Flr-Room G2 Sink Faucet, First Draw	0.001	<0.001	mg/L	
240318R010	10	Grd Flr-Room G2 Sink Faucet, 30s Flush	0.001	<0.001	mg/L	
240318R011	11	Grd Flr-Room G3 Sink Faucet, First Draw	0.001	0.014	mg/L	
240318R012	12	Grd Flr-Room G3 Sink Faucet, 30s Flush	0.001	0.002	mg/L	
240318R013	13	Grd Flr-G3 Bath Sink Faucet, First Draw	0.001	<0.001	mg/L	
240318R014	14	Grd Flr-G3 Bath Sink Faucet, 30s Flush	0.001	<0.001	mg/L	
240318R015	15	Grd Flr-Hall Bath 1 Sink Faucet, First Draw	0.001	0.003	mg/L	
240318R016	16	Grd Flr-Hall Bath 1 Sink Faucet, 30s Flush	0.001	<0.001	mg/L	
240318R017	17	Grd Flr-Hall Bath 2 Sink Faucet, First Draw	0.001	0.015	mg/L	
240318R018	18	Grd Flr-Hall Bath 2 Sink Faucet, 30s Flush	0.001	<0.001	mg/L	
240318R019	19	Grd Flr-Therapy Bathroom Sink Faucet, First Draw	0.001	0.008	mg/L	
240318R020	20	Grd Flr-Therapy Bathroom Sink Faucet, 30s Flush	0.001	0.002	mg/L	
240318R021	21	Grd Flr-Room G4 Sink Faucet, First Draw	0.001	0.003	mg/L	
240318R022	22	Grd Flr-Room G4 Sink Faucet, 30s Flush	0.001	0.002	mg/L	
240318R023	23	1st Flr- Girls Bath Sink R, First Draw	0.001	<0.001	mg/L	
240318R024	24	1st Flr- Girls Bath Sink R, 30s Flush	0.001	<0.001	mg/L	



Date Received:	18 Mar 2024
Date Analyzed:	19 Mar 2024

Analytical Method:	EPA 200.9 Rev. 2.2
OCFS Provider ID	2401640
Analyte, Matrix:	Lead, Potable Water

Lab ID	Client ID	Sample Location/Description	LOQ	Result	Units	Flag
240318R025	25	1st Flr- Girls Bath Sink M, First Draw	0.001	<0.001	mg/L	
240318R026	26	1st Flr- Girls Bath Sink M, 30s Flush	0.001	<0.001	mg/L	
240318R027	27	1st Flr- Girls Bath Sink L, First Draw	0.001	<0.001	mg/L	
240318R028	28	1st Flr- Girls Bath Sink L, 30s Flush	0.001	<0.001	mg/L	
240318R029	29	Room 106 Sink R, First Draw	0.001	<0.001	mg/L	
240318R030	30	Room 106 Sink R, 30s Flush	0.001	<0.001	mg/L	
240318R031	31	Room 106 Sink L, First Draw	0.001	<0.001	mg/L	
240318R032	32	Room 106 Sink L, 30s Flush	0.001	<0.001	mg/L	
240318R033	33	Room 104 Sink R, First Draw	0.001	<0.001	mg/L	
240318R034	34	Room 104 Sink R, 30s Flush	0.001	<0.001	mg/L	
240318R035	35	Room 104 Sink L, First Draw	0.001	<0.001	mg/L	
240318R036	36	Room 104 Sink L, 30s Flush	0.001	<0.001	mg/L	
240318R037	37	Room 102 Sink R, First Draw	0.001	<0.001	mg/L	
240318R038	38	Room 102 Sink R, 30s Flush	0.001	<0.001	mg/L	
240318R039	39	Room 102 Sink L, First Draw	0.001	<0.001	mg/L	
240318R040	40	Room 102 Sink L, 30s Flush	0.001	<0.001	mg/L	
240318R041	41	Nurse Office Sink Faucet, First Draw	0.001	0.010	mg/L	
240318R042	42	Nurse Office Sink Faucet, 30s Flush	0.001	0.001	mg/L	
240318R043	43	Mens Bath Sink R, First Draw	0.001	<0.001	mg/L	
240318R044	44	Mens Bath Sink R, 30s Flush	0.001	<0.001	mg/L	
240318R045	45	Mens Bath Sink L, First Draw	0.001	<0.001	mg/L	
240318R046	46	Mens Bath Sink L, 30s Flush	0.001	<0.001	mg/L	
240318R047	47	Womans Bath Sink R, First Draw	0.001	0.003	mg/L	
240318R048	48	Womans Bath Sink R, 30s Flush	0.001	<0.001	mg/L	
240318R049	49	Womans Bath Sink M, First Draw	0.001	0.002	mg/L	



Date Received:	18 Mar 2024
Date Analyzed:	19 Mar 2024

Analytical Method:	EPA 200.9 Rev. 2.2
OCFS Provider ID	2401640
Analyte, Matrix:	Lead, Potable Water

Lab ID	Client ID	Sample Location/Description	LOQ	Result	Units	Flag
240318R050	50	Womans Bath Sink M, 30s Flush	0.001	<0.001	mg/L	
240318R051	51	Womans Bath Sink L, First Draw	0.001	0.001	mg/L	
240318R052	52	Womans Bath Sink L, 30s Flush	0.001	<0.001	mg/L	
240318R053	53	2nd Flr-KIT Sprayer, First Draw	0.001	0.002	mg/L	
240318R054	54	2nd Flr-KIT Sprayer, 30s Flush	0.001	0.001	mg/L	
240318R055	55	2nd Flr-Mens Bath-1 Sink Faucet, First Draw	0.001	<0.001	mg/L	
240318R056	56	2nd Flr-Mens Bath-1 Sink Faucet, 30s Flush	0.001	<0.001	mg/L	
240318R057	57	2nd Flr-Mens Bath-2 Sink Faucet, First Draw	0.001	<0.001	mg/L	
240318R058	58	2nd Flr-Mens Bath-2 Sink Faucet, 30s Flush	0.001	<0.001	mg/L	
240318R059	59	2nd Flr-Mens Bath-3 Sink Faucet, First Draw	0.001	<0.001	mg/L	
240318R060	60	2nd Flr-Mens Bath-3 Sink Faucet, 30s Flush	0.001	<0.001	mg/L	
240318R061	61	2nd Flr-Womans R Sink Faucet, First Draw	0.001	0.012	mg/L	
240318R062	62	2nd Flr-Womans R Sink Faucet, 30s Flush	0.001	0.001	mg/L	
240318R063	63	2nd Flr-Womans M Sink Faucet, First Draw	0.001	<0.001	mg/L	
240318R064	64	2nd Flr-Womans M Sink Faucet, 30s Flush	0.001	<0.001	mg/L	
240318R065	65	2nd Flr-Womans L Sink Faucet, First Draw	0.001	0.001	mg/L	
240318R066	66	2nd Flr-Womans L Sink Faucet, 30s Flush	0.001	<0.001	mg/L	
240318R067	67	2nd Flr- WomansWall by itself Sink Faucet, First Draw	0.001	<0.001	mg/L	
240318R068	68	2nd Flr- WomansWall by itself Sink Faucet, 30s Flush	0.001	<0.001	mg/L	
240318R069	69	Field Blank	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

