

Laboratory Report
NYE Report #: 2401724-28954

March 25, 2024

Chautauqua Opportunities Inc. Connections North
17 West Courtney St.
Dunkirk, NY

Project: OCFS Water Testing
OCFS Provider: 42848

Dear Chautauqua Opportunities Inc. Connections North,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on March 21, 2024. New York Environmental analyzed the samples on March 22, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.


The USEPA-designated action level for Lead (Pb) in potable water is 0.015 milligrams per liter (0.015 mg/L). The concentration of lead in your samples is listed under the "Result" column.

If there are any further questions regarding the analyses, please feel free to contact us at your convenience at laboratory@nyenvironmental.com. Please include your report number in the subject line of any correspondence.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

We sincerely thank you for participating in the program, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Received:	21 Mar 2024
Date Analyzed:	22 Mar 2024

Analytical Method:	EPA 200.9 Rev. 2.2
OCFS Provider ID	2401724
Analyte, Matrix:	Lead, Potable Water

Lab ID	Client ID	Sample Location/Description	LOQ	Result	Units	Flag
240321L065	1	Red Room Sink Faucet, First Draw	0.001	<0.001	mg/L	
240321L066	2	Red Room Sink Faucet, 30s Flush	0.001	<0.001	mg/L	
240321L067	3	Shared Bath Sink Faucet R, First Draw	0.001	<0.001	mg/L	
240321L068	4	Shared Bath Sink Faucet R, 30s Flush	0.001	<0.001	mg/L	
240321L069	5	Shared Bath Sink Faucet L, First Draw	0.001	<0.001	mg/L	
240321L070	6	Shared Bath Sink Faucet L, 30s Flush	0.001	<0.001	mg/L	
240321L071	7	Blue Room Sink Faucet, First Draw	0.001	<0.001	mg/L	
240321L072	8	Blue Room Sink Faucet, 30s Flush	0.001	<0.001	mg/L	
240321L073	9	Yellow Room Sink Faucet, First Draw	0.001	<0.001	mg/L	
240321L074	10	Yellow Room Sink Faucet, 30s Flush	0.001	<0.001	mg/L	
240321L075	11	Shared Bath Sink Faucet R, First Draw	0.001	<0.001	mg/L	
240321L076	12	Shared Bath Sink Faucet R, 30s Flush	0.001	<0.001	mg/L	
240321L077	13	Shared Bath Sink Faucet L, First Draw	0.001	<0.001	mg/L	
240321L078	14	Shared Bath Sink Faucet L, 30s Flush	0.001	<0.001	mg/L	
240321L079	15	Grey Room Sink Faucet, First Draw	0.001	<0.001	mg/L	
240321L080	16	Grey Room Sink Faucet, 30s Flush	0.001	<0.001	mg/L	
240321L081	17	Green Room Sink Faucet, First Draw	0.001	<0.001	mg/L	
240321L082	18	Green Room Sink Faucet, 30s Flush	0.001	<0.001	mg/L	
240321L083	19	Shared Bath Sink Faucet R, First Draw	0.001	0.005	mg/L	
240321L084	20	Shared Bath Sink Faucet R, 30s Flush	0.001	<0.001	mg/L	
240321L085	21	Shared Bath Sink Faucet L, First Draw	0.001	0.002	mg/L	
240321L086	22	Shared Bath Sink Faucet L, 30s Flush	0.001	<0.001	mg/L	
240321L087	23	Orange Room Sink Faucet, First Draw	0.001	<0.001	mg/L	
240321L088	24	Orange Room Sink Faucet, 30s Flush	0.001	<0.001	mg/L	



Date Received:	21 Mar 2024
Date Analyzed:	22 Mar 2024

Analytical Method:	EPA 200.9 Rev. 2.2
OCFS Provider ID	2401724
Analyte, Matrix:	Lead, Potable Water

Lab ID	Client ID	Sample Location/Description	LOQ	Result	Units	Flag
240321L089	25	Teal Room Kitchen Sink Faucet, First Draw	0.001	<0.001	mg/L	
240321L090	26	Teal Room Kitchen Sink Faucet, 30s Flush	0.001	<0.001	mg/L	
240321L091	27	Teal Room Sink Faucet, First Draw	0.001	0.001	mg/L	
240321L092	28	Teal Room Sink Faucet, 30s Flush	0.001	<0.001	mg/L	
240321L093	29	Shared Bath R Sink Faucet, First Draw	0.001	0.001	mg/L	
240321L094	30	Shared Bath R Sink Faucet, 30s Flush	0.001	<0.001	mg/L	
240321L095	31	Shared Bath L Sink Faucet, First Draw	0.001	0.002	mg/L	
240321L096	32	Shared Bath L Sink Faucet, 30s Flush	0.001	<0.001	mg/L	
240321L097	33	Purple Room Kitchen Sink Faucet, First Draw	0.001	<0.001	mg/L	
240321L098	34	Purple Room Kitchen Sink Faucet, 30s Flush	0.001	<0.001	mg/L	
240321L099	35	Purple Room Sink Faucet, First Draw	0.001	<0.001	mg/L	
240321L100	36	Purple Room Sink Faucet, 30s Flush	0.001	<0.001	mg/L	
240321L101	37	Nurse Office Sink Faucet, First Draw	0.001	0.001	mg/L	
240321L102	38	Nurse Office Sink Faucet, 30s Flush	0.001	<0.001	mg/L	
240321L103	39	Conference Room Sink Faucet, First Draw	0.001	0.001	mg/L	
240321L104	40	Conference Room Sink Faucet, 30s Flush	0.001	<0.001	mg/L	
240321L105	41	Water Fountain R Sink Faucet, First Draw	0.001	<0.001	mg/L	
240321L106	42	Water Fountain R Sink Faucet, 30s Flush	0.001	<0.001	mg/L	
240321L107	43	Water Fountain L Sink Faucet, First Draw	0.001	<0.001	mg/L	
240321L108	44	Water Fountain L Sink Faucet, 30s Flush	0.001	<0.001	mg/L	
240321L109	45	Kitchen Hand Wash Sink, First Draw	0.001	<0.001	mg/L	
240321L110	46	Kitchen Hand Wash Sink, 30s Flush	0.001	<0.001	mg/L	
240321L111	47	Kitchen 3 Bay Sink, First Draw	0.001	0.019	mg/L	H
240321L112	48	Kitchen 3 Bay Sink, 30s Flush	0.001	<0.001	mg/L	
240321L113	49	Kitchen Dishwasher Sprayer Sink, First Draw	0.001	0.004	mg/L	



Date Received:	21 Mar 2024
Date Analyzed:	22 Mar 2024

Analytical Method:	EPA 200.9 Rev. 2.2
OCFS Provider ID	2401724
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>Client ID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
240321L114	50	Kitchen Dishwasher Sprayer Sink, 30s Flush	0.001	<0.001	mg/L	
240321L115	51	Kitchen Vegetable Sink, First Draw	0.001	<0.001	mg/L	
240321L116	52	Kitchen Vegetable Sink, 30s Flush	0.001	<0.001	mg/L	
240321L117	53	Field Blank	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.

